



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	12/19/11	Interpretation	11-023
Topic	Access-controlled egress doors		
Code Section(s)	2010 CBC 1008.1.4.4 & CFC 1008.1.4.4		
Requested by	Steven Hoffman Building Knowledge, Founder, Lead Instructor 119 Verde Meas Dr. Danville, CA 94526 steve@IORED.com		

Does Section 1008.1.4.4 item # 6 apply only to entrance doors to buildings with occupancies A, B, I-2 or M and not to entrance doors to tenant spaces?

Yes